# **SCOPE OF WORK**

REMOVE/REPLACE
EMERGENCY GENERATOR
FDOT LEESBURG OPERATIONS COMPLEX
1405 THOMAS AVE.
LEESBURG, FL. 34748
PROJECT NO. 422343-4-52-01, 422343-5-52-01
CONTRACT NUMBER E-5L20
LAKE COUNTY

#### 1.0 **PURPOSE:**

The Florida Department of Transportation, District Five, requires the services of a Licensed Electrical Contractor to Remove and Replace the existing Emergency Generator at their Leesburg Operations Complex located at 1405 Thomas Ave., Leesburg, Fl. 34748

## 2.0 BID SUBMITTAL:

- 1. Bids shall be submitted in accordance with supplied Electrical Engineer Plans and Specifications and should adhere to requirements of the Departments Bid Request Documents, Fixed Capital Outlay Non-Technical Specifications and this Scope.
- 2. The Department has procured a new Cummins 400kw generator and three ASCO transfer switches which will replace the existing equipment. This project consists of the removal of existing equipment and installation of new equipment as detailed in the furnished Plans and Specifications. Contractors shall include all aspects of this installation project as part of the bid which include, but not limited to: Cost to off load new generator, Cost for permits/fees including review of State Fire Marshal if necessary, Tools, Labor, and Materials necessary to complete the installation.

#### 3.0 MANDATORY PRE-BID MEETING:

1. A mandatory pre-bid meeting will be held Tuesday, March 17, 2015, 10:00am, at the FDOT Leesburg Operations Complex located at 1405 Thomas Ave., Leesburg, Fl. 34748.

## 4.0 **WORK HOURS:**

1. The majority of work shall be accomplished during the Departments standard work hours, 7:00am – 5:00pm Monday through Friday. The period of time needed to switch over power shall be accomplished on a Friday between the hours of 8:00am - 5:00pm.

# 5.0 **CONTRACT TIME:**

1. Reference section A-21, page 11, FCO Non-Technical Specifications Package.

# 6.0 <u>ADMINISTRATION:</u>

1. Unless otherwise noted in writing, all administrative issues for this project shall be governed by the Fixed Capital Outlay Non-Technical Specifications Package attached herein.